

GENERAL ARRANGEMENT DRAWINGS

SUBSTATION TYPE	TITLE	DRG No.	REVISION
N/A	EARTH POINT CONNECTION DETAILS	C978643	REV.B
COLD	315 - 1000KVA SLIDE IN UDE - INTEGRAL EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1065495	REV.A
COLD	315 - 1000KVA SLIDE IN UDE WITH CUSTOMER LV MCCB EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1024527	REV.C
COLD	315 - 1000KVA SLIDE IN UDE EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010793	REV.C
COLD	800 - 1000KVA UDE EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010820	REV.C
COLD	11KV EXTENSIBLE HV PANEL WITH METERING ANNEXE EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010822	REV.C
COLD	11KV RMU CABLE CONNECTED 1600KVA TX AND 2500A MCCB EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010824	REV.C
COLD	11KV RMU AND METERING UNIT WITH OPTIONAL EXTENSIBLE SW EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010827	REV.C
COLD	20KV RMU CABLE CONNECTED 1600KVA TX AND 2500A MCCB EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010839	REV.C
COLD	20KV EXTENSIBLE HV PANEL WITH METERING ANNEXE EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010841	REV.C
COLD	20KV DISTRIBUTION SUBSTATION EARTHING ARRANGEMENT - COMBINED SITE (COLD)	C1010842	REV.C
HOT	315 - 1000KV SLIDE IN UDE EARHTING ARRANGEMENT - SEPERATE SITE (HOT)	C1010854	REV.C
HOT	315 - 1000KVA SLIDE IN UDE WITH CUSTOMER LV MCCB EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1024607	REV.C
HOT	11KV RMU CABLE CONNECTED 1600KVA TX AND 2500A MCCB EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010855	REV.D
HOT	20KV RMU CABLE CONNECTED 1600KVA TX AND 2500A MCCB EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010858	REV.D
HOT	800 - 1000KVA UDE EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010864	REV.C
HOT	20KV DISTRIBUTION SUBSTATION EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010867	REV.C
HOT	11KV RMU AND METERING UNIT WITH OPTIONAL EXTENSIBLE SW EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010868	REV.C
HOT	20KV EXTENSIBLE HV PANEL WITH METERING ANNEXE EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010869	REV.C
HOT	11KV EXTENSIBLE HV PANEL WITH METERING ANNEXE EARTHING ARRANGEMENT - SEPERATE SITE (HOT)	C1010879	REV.C
N/A	EARTHING CONNECTION POINT EXAMPLES FOR POLICY IMP/010/011	C1010947	REV.A
N/A	RMU CABLE SHEATH BONDING	C1040519	REV.D

NORTHERN POWERGRID Manufacturer Details		Lloyds Court, 78 Grey Street, Newcastle Upon Tyne, NE1 6AF			
		SCHEDULE OF DRAWINGS			
		EARTHING ARRANGEMENTS FOR POLICY IMP/010/011			
Sheet No.	Scale				
1	N.T.S.				
Prepared By Barbara Rimmer			Type		
		PLANT DIAGRAMS		WIRING	
Revised 02/1/17	Grid Reference	Ref No.	C1010944	Historic Drg.No.	C1010944
Date Issued 03/07/12	Checked By S CRAWFORD	Revision	E	Notes	