

Threat Type	Threat Type 2	Data Source	Data Type	Available Data			UKCP18 Update	Detail of Risks / Opportunities				Now		Risk Assessment						Actions			Comments																																																																																																																																																																																							
				Current	2030s	2050s		2080s	Asset Type	Projected direct or indirect impact	Risks and Opportunities	Consequences	Stakeholder impacts	Likelihood	Impact	Current Risk	Likelihood	Impact	Medium Term Risk	Likelihood	Impact	Long Term Risk		Status	Details	Timescale (planned & potential actions)																																																																																																																																																																																				
				2020s	2030s	2050s		2080s	Asset Type	Projected direct or indirect impact	Risks and Opportunities	Consequences	Stakeholder impacts	Likelihood	Impact	Current Risk	Likelihood	Impact	Medium Term Risk	Likelihood	Impact	Long Term Risk		Status	Details	Timescale (planned & potential actions)																																																																																																																																																																																				
Extreme Event	Flooding (fluvial)	EA Flooding Risk Maps	Detailed site by site analysis	No future predictions available				Substation	Change in flood plains	Increased area of flood plain	Increased exposure as more sites encapsulated in flood plain.	Loss of substation equipment leading to loss of supplies to customers	3	Possible	3	Moderate	9	3	Possible	3	Moderate	9	4	Likely	4	Significant	16	In place	Flood defence policy in place in line with ETR138	Northern Powergrid has implemented a flood defence programme in line with the recommendations of ETR138. ETR138 includes provision for climate change. There is currently no flood plain prediction data available for use. Flood defence provision will be reviewed as and when future predictors for flood plains are published.																																																																																																																																																																																
																															Transformers	Change in flood plains	Substation floods detailed above	Transformer faults due to floodwater (failure likely to be due to cable terminations, cooling fans, secondary wiring or aux switches)	Loss of transformer leading to loss of supplies to customers	3	Unlikely	3	Moderate	9	3	Possible	3	Moderate	9	4	Likely	4	Significant	16	In place	Flood defence policy in place in line with ETR138																																																																																																																																																										
																																																					Circuit Breakers	Change in flood plains	Substation floods detailed above	Switchgear faults due to floodwater (failure likely to be due to cable terminations, secondary wiring or aux switches)	Loss of circuit breakers leading to loss of supplies to customers	3	Unlikely	3	Moderate	9	3	Possible	3	Moderate	9	4	Likely	4	Significant	16	In place	Flood defence policy in place in line with ETR138																																																																																																																																				
																																																																											Overhead Lines	Change in flood plains	Increased area of flood plain	Clearances potentially reduced during flooding event	Increased risk of third party contact with overhead lines during a flood event	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	In place	Regular condition assessments of breakers carried out to prioritise replacement.																																																																																																														
																																																																																																	Underground Cables	Change in flood plains	Increased area of flood plain	Land surrounding cables is flooded or waterlogged	Additional cable faults occur leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	Potential	Identify and relocate / protect at risk structures																																																																																								
																																																																																																																							Protection	Change in flood plains	Substation floods detailed above	Protection fails due to floodwater	Protection fails to operate during a fault leading to a unsafe conditions on the network.	3	Possible	3	Moderate	9	3	Possible	3	Moderate	9	4	Likely	4	Significant	16	In place	Flood defence policy in place in line with ETR138																																																																		
																																																																																																																																													Earthing	Change in flood plains	Floodwater blocks site access	Personnel cannot access sites to assess / remedy fault situations	Extended fault durations	2	Unlikely	3	Moderate	6	3	Possible	3	Moderate	9	4	Likely	3	Moderate	12	Potential	Review of emergency planning procedures																																												
																																																																																																																																																																			Vegetation Mgt	Change in flood plains	Increased risk and severity of flooding events	Disruption to routine activities due to re-allocation of resources and access issues	Planned work not delivered on time. Maintenance behind schedule	2	Unlikely	2	Minor	4	3	Possible	2	Minor	6	4	Likely	2	Minor	4	Potential	Targeted vegetation management of at risk trees																						
																																																																																																																																																																																									Routine Business (Maintenance, R&M, Capital Investment)	Change in flood plains	Increased risk and severity of flooding events	Disruption to routine activities due to re-allocation of resources and access issues	Planned work not delivered on time. Maintenance behind schedule	2	Unlikely	3	Moderate	6	3	Possible	3	Moderate	9	4	Likely	3	Moderate	12	In place	Flood defence policy in place in line with ETR138

Threat Type	Threat Type 2	Data Source	Data Type	Available Data				UKCP18 Update	Details of Risks / Opportunities				Risk Assessment										Actions	Timescale (planned & potential actions)	Comments										
				Current	2020s	2050s	2080s		Asset Type	Projected direct or indirect impact	Risks and Opportunities	Consequences	Stakeholder impacts	Likelihood	Impact	Current Risk	2020s		2050s		2080s					Long Term Risk	Status	Details							
Coastal Flooding	CEEA Flood B Coastal Defence Assets (England, Scotland, Northern Ireland) (North of Plumborough Head)	Met sea level rise (mm-yr) (NW England, NE Scotland)	2.3 (1990-2025)	7 (2025-2055)	10 (2055-2085)	13 (2085-2115)	Sea level currently rising with central projections up to 1m by 2100. No change predicted in storm surge, any changes in extreme sea level are the result of sea level rise as opposed to atmospheric stormwaves.	Substations	EA coastal defence fail	Substations flooded leading to loss of supplies	Loss of substation equipment leading to loss of supplies to customers	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	The area of the number estuary currently carries a low flood risk. If the sea defences were to fail then the entire area would be under water. It is considered impossible to mitigate against as the cost of defending our assets is considered disproportionate.						
									Sea water overtop EA coastal defence	Substations flooded leading to loss of supplies	Loss of substation equipment leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Transformer fails due to floodwater (failure likely to be due to cable termination, cooling fans, secondary wiring or bus switches)	Loss of transformer leading to loss of supplies to customers	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely		3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Transformer fails due to floodwater (failure likely to be due to cable termination, cooling fans, secondary wiring or bus switches)	Loss of transformer leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Switchgear fails due to floodwater (failure likely to be due to cable termination, secondary wiring or bus switches)	Loss of circuit breakers leading to loss of supplies to customers	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely		3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Switchgear fails due to floodwater (failure likely to be due to cable termination, secondary wiring or bus switches)	Loss of circuit breakers leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Increased humidity following flood event	High levels of partial discharge	Increased maintenance required, potentially shortened asset life.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely		1	Limited	2	2	In place	Regular condition assessments of breakers carried out to prioritise replacement.
									EA coastal defence fail	Clearances potentially reduced during event	Increased risk of third party contact with overhead lines during a flood event	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely		3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Clearances potentially reduced during event	Increased risk of third party contact with overhead lines during a flood event	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Prolonged submersion in water causing water ingress	Additional cable faults occur leading to loss of supplies to customers	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Prolonged submersion in water causing water ingress	Additional cable faults occur leading to loss of supplies to customers	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Prolonged submersion in water causing water ingress to link boxes	Link box faults occur leading to loss of supplies to customers	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Prolonged submersion in water causing water ingress to link boxes	Link box faults occur leading to loss of supplies to customers	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Prolonged submersion in water causing water ingress to link boxes	Link box faults occur leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Prolonged submersion in water causing water ingress to link boxes	Link box faults occur leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Protection fails due to floodwater	Safety implications during a flooding event	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely		3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Protection fails due to floodwater	Safety implications during a flooding event	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Prolonged submersion in water causing water ingress	Earthing connections fail leading to increased risk	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Prolonged submersion in water causing water ingress	Earthing connections fail leading to increased risk	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Prolonged submersion in water causing water ingress	Earthing connections fail leading to increased risk	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Prolonged submersion in water causing water ingress	Earthing connections fail leading to increased risk	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Roads flooded leading to difficulties in reaching & repairing network faults	Additional faults on the network.	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely	3	Moderate	3	1	Very Unlikely		3	Moderate	3	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									Sea water overtop EA coastal defence	Roads flooded leading to difficulties in reaching & repairing network faults	Additional faults on the network.	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely		2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site	
									EA coastal defence fail	Roads flooded leading to difficulties in reaching & repairing network faults	Routine activities delayed.	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely		2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site	
Sea water overtop EA coastal defence	Roads flooded leading to difficulties in reaching & repairing network faults	Routine activities delayed.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Sea level rise over life of assets considered when implementing flood defences at site										
EA coastal defence fail	Roads flooded leading to difficulties in reaching & repairing network faults	Additional faults on the network.	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	In place	Sea level rise over life of assets considered when implementing flood defences at site											
Sea water overtop EA coastal defence	Roads flooded leading to difficulties in reaching & repairing network faults	Additional faults on the network.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Sea level rise over life of assets considered when implementing flood defences at site										
EA coastal defence fail	Combination of ice and wind causes damage to substation buildings	Failure of equipment becomes damaged or falling debris	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Sea level rise over life of assets considered when implementing flood defences at site										
Sea water overtop EA coastal defence	Ice build up causes access problems etc to freeze	Increased fault duration.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Sea level rise over life of assets considered when implementing flood defences at site										
EA coastal defence fail	Combination of temperature and wind conditions conducive to ice formation	Ice build up occurs on transformers	Operation of transformers compromised by ice affecting exposed moving parts on equipment in outdoor compounds (e.g. cooling fan operation, blocked radiator fins)	Loss of transformer leading to loss of supplies to customers	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Sea level rise over life of assets considered when implementing flood defences at site								
Sea water overtop EA coastal defence	Combination of temperature and wind conditions conducive to ice formation	Ice build up occurs on switchgear	Operation of switchgear compromised by ice affecting exposed moving parts on equipment in outdoor compounds	Loss of circuit breakers leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Existing EMATs specifications include test with 'Onion of ice on all parts'									
EA coastal defence fail	Combination of temperature and wind conditions conducive to ice loading	Ice build up occurs on Overhead Lines	Lines and structures compromised by ice loadings	Additional overhead line faults leading to loss of supplies to customers	3	Possible	3	Moderate	3	3	Possible	3	Moderate	3	3	Possible	3	Moderate	3	3	Possible	3	Moderate	3	In place	EU Research COST 727 looked at snow/ice loading of overhead lines. Existing designs have adequate structural strength.									
Sea water overtop EA coastal defence	Atmospheric conditions not conducive to helicopter flight	Unable to operate helicopters to carry out fault location	Fault location time increased	Fault durations increased due to lengthened location times.	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site									
EA coastal defence fail	Water ingress	Freezing of water	Termination faults due to freezing	Termination faults cause loss of supplies	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site									
Sea water overtop EA coastal defence	Water separates stress control components	Water separates stress control components	Failure causes loss of supplies	Failure causes loss of supplies	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site									
EA coastal defence fail	Freezing within silicon oil terminations	Freezing within silicon oil terminations causing water to leak to high stress areas of terminations	Termination faults	Termination faults cause loss of supplies	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Sea level rise over life of assets considered when implementing flood defences at site									
EA coastal defence fail	Increased frequency of events	WHP conditions occur on a more regular basis	WHP begins to become business as usual	Resource re-allocated more regularly leading to impact on business as usual.	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	In place	Emergency plans in place.									
Sea water overtop EA coastal defence	Combination of temperature and wind conditions conducive to ice loading	Vegetation suffers due to conditions	Additional faults due to vegetation encroachment	Safety risk due to compromised structural integrity or broken conductors	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	In place	Vegetation programmes in place.									
EA coastal defence fail	Increased frequency of events	Routine maintenance suffers as a result of additional faults	Fault repairs become a greater part of workload	Regulatory criticism as work planned is not completed due to diversion of funds to elsewhere	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	In place	Sea level rise over life of assets considered when implementing flood defences at site									
Sea water overtop EA coastal defence	Combination of temperature and wind conditions conducive to snow build up	General snow & ice build up	Slow response times due to problematic access	Increased fault durations. Safety risk as staff due to weather conditions.	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	In place	Sea level rise over life of assets considered when implementing flood defences at site									

Threat Type	Threat Type	Data Source	Data Type	Available Data				UKCP18 Update	Detail of Risks / Opportunities				Risk Assessment						Actions		Comments																			
				Current	2020s	2050s	2080s		Asset Type	Projected direct or indirect impact	Risks and Opportunities	Consequences	Stakeholder	Likelihood	Impact	Current Risk	2020s	2050s	2080s	Long Term Risk		Status	Details	Timescale (planned & potential actions)																
Heavy snow	UKCP09 Met Office	Mean winter (temperature) (central estimate)	Wind Speed	3.1°C	All emissions scenarios: L: 5.0°C H: 5.3°C H: 5.6°C	No increase forecast in the severity of high wind events	No increase forecast in the severity of high wind events	No increase forecast in the severity of high wind events	Under RCP6.0 and 8.5 scenarios, warming forecast in the UKCP09 high and medium scenarios for our region. Reduced warming forecast under lower scenarios. Downward trend in winter mean snowfall and lying snow through time with almost 100% reduction in lying snow in lowland areas by the end of the century. Events may still occur though. No trend to forecast increase in wind speeds. 10-20% increase in the days of strong winds over the UK by 2070-2100 compared to 1975-2005 under worst case scenario	Substations	Build up of snow on lines and roads	Substation buildings (particularly flat roofed structures) unable to take weight of snow build up	Buildings and structures fail	Falling debris or power to snow causes substation equipment to fail leading to loss of supplies	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2											
				Transformers	Build up of snow around outdoor equipment	Transformer ratings and/or pumps and fans unable to operate due to snow	Transformer ratings reduced or transformer fails	Unable to meet required demand. Customers off supply.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2												
				Circuit Breakers	Build up of snow around outdoor equipment	Switchgear moving parts unable to operate due to snow	Failure of switchgear leads to customers off supply.	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	In place	Existing EMHTS specifications include test with 10mm of ice on all parts										
				Overhead Lines	Combination of temperature and wind conditions conducive to snow build up	Snow & ice build up occurs on overhead lines	Lines and structures compromised by loadings	Additional overhead line faults Safety risk due to compromised structural integrity or broken conductors	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Moderate	4	2	In place	EU Research COST 727 looking at new snow loading of overhead lines. Expectations are that existing designs have adequate structural strength.	To be reviewed following completion of EU research COST 727													
				Underground Cables	Met causes excess water	Water ingress to occurs	Additional cable faults occur due to water ingress	Loss of substation equipment leading to loss of supplies to customers	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2											
				Protection	Met causes excess water	Water ingress to occurs	Earthing may become less effective	Safety risks	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2											
				Emergency Response & Planning	Combination of temperature and wind conditions conducive to snow build up	General snow & ice build up	Additional faults occur due to snow build up	Increased number of faults and duration of faults. Safety risk to staff due to weather conditions.	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	In place	Review of emergency planning procedures	In line with ongoing climate change predictions													
				Vegetation Mgt	Combination of temperature and wind conditions conducive to snow build up	Snow & ice build up occurs on vegetation	Additional faults caused by broken trees	Increased number of faults Safety risk due to compromised structural integrity or broken conductors	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	In place	Vegetation programmes in place.														
				Routine Business (Maintenance, R&R, Capital Investment)	Combination of temperature and wind conditions conducive to snow build up	General snow & ice build up	Access restricted and reduced workforce	Unable to carry out business as usual due to access and travel difficulties.	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2																
				Customer Service	Combination of temperature and wind conditions conducive to snow build up	General snow & ice build up	Slow response times due to problematic access	Increased fault durations. Safety risk to staff due to weather conditions.	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	Unlikely	3	Moderate	6	2	In place	Review of business as usual procedures	In line with ongoing climate change predictions													
Hurricane & other high wind events	Met Office	Wind Speed	No increase forecast in the severity of high wind events	No increase forecast in the severity of high wind events	No increase forecast in the severity of high wind events	No trend to forecast increase in wind speeds. 10-20% increase in the days of strong winds over the UK by 2070-2100 compared to 1975-2005 under worst case scenario	Substations	Increased frequency of high wind events weakens or damages substation structure	Damage occurs to substation buildings	Safety risk to staff and public due to falling objects or compromised structure	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Substation inspections to ensure integrity of structures and remedy issues								
							Transformers	High winds cause falling debris	Debris falls onto transformer and/or flashover	Transformer faults cause loss of supply to customers.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2					
							Circuit Breakers	High winds cause falling debris	Debris falls onto switchgear causing damage	Switchgear faults causing loss of supply to customers	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2					
							Overhead Lines	Increased frequency of high wind events weakens poles and fittings	More damage occurs to overhead line networks	Additional faults occur on overhead line networks	Increased overhead line faults. Safety risk to public and staff due to falling and fallen poles and conductors	3	Possible	3	Moderate	9	3	Possible	3	Moderate	9	3	Possible	3	Moderate	9	3	Potential	Refurbishment programme to ensure integrity of the overhead network	Ongoing - as changes are observed and finer data published										
							Underground Cables																																	
							Protection																																	
							Emergency Response & Planning	Increased frequency of high wind events	Additional incidents occur	Resources strained in order to meet demand on fault repairs	Duration of faults increased due to limited resources	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Potential	Review thresholds for major incidents.	As required in line with observed trends.										
							Vegetation Mgt	Increased frequency of high wind events weakens vegetation	More damage occurs to vegetation	Additional faults occur due to vegetation damage to lines	Increased number of faults due to vegetation	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Vegetation management programme in place											
							Routine Business (Maintenance, R&R, Capital Investment)	High winds prevent certain types of routine activity	Routine activity specifically on overhead lines delayed as a result of unsuitable weather conditions	Routine activities delayed	Routine activities delayed.	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	In place	Additional work costing through Paycom. Annual review of investment plan takes account of these changes.											
							Customer Service	High winds cause additional faults	Routine activity delayed as a result of dealing with additional faults	Work declared as part of regulatory price as work planned is not completed due to diversion of funds to elsewhere	Regulatory price as work planned is not completed due to diversion of funds to elsewhere	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2													
Extreme prolonged temperature periods (heat wave)	UKCP09 Met Office	Mean summer (temperature) (central estimate)	14.2°C	L: 15.6°C H: 15.5°C H: 15.3°C	L: 16.4°C H: 16.5°C H: 16.8°C	L: 17.7°C H: 17.5°C H: 18.4°C	RCP6.0 projects a greater increase in summer mean temperature than the UKCP09 high scenario for our region. RCP6.0 is in line with the UKCP09 medium scenario and RCP4.5 with the low scenario. Analysis has been done on the number of days exceeding 28, 30 and 35 degrees celsius. In the current climate it is relatively rare for a day to exceed 30 degrees celsius in our region. The temperature exceeds 28 degrees for 3 consecutive days on average 4 times per annum. By mid century, the chance of a hot summer like 2018 will have increased from 10% to 20%. Largest increases in temperature will occur in South East England. By 2060, the increase from temperature for our region are expected to be equivalent to SE England today.	Substations	Ambient temperature at a sustained high level	Additional load placed on substation due to the connection of air conditioning	Insufficient available capacity for load	Potential load shedding or loss of transformer due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Current spec calls for full testing at 30°C ambient temperature	All Northern Powergrid equipment is built to international, European and British standards which incorporate an amount of resilience. Due to the current varied global conditions, all standards currently allow for the equipment to operate in conditions which exceed those forecast to occur in the Northern Powergrid region over the time period under consideration.					
								Transformers	Ambient temperature at a sustained high level	Capacity of transformer reduced due to high ambient temperature	Insufficient available capacity for load	Potential load shedding or loss of transformer due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Annual review of loading of transformers against maximum demands to ensure adequate headroom on the network	
								Overheating of tap changer control mechanism	Tripping of tap changer	Loss of supplies	3	Possible	1	Limited	3	3	Possible	1	Limited	3	3	Possible	1	Limited	3	3	Possible	1	Limited	3	3	Possible	1	Limited	3	Potential	Amend specification to include sanctions for new equipment. Retire fit scheme for existing.			
								Additional load placed on transformer due to connection of air conditioning	Insufficient available capacity for load	Potential load shedding or loss of transformer due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Annual review of loading of transformers against maximum demands to ensure adequate headroom on the network			
								Circuit Breakers	Ambient temperature at a sustained high level	Additional load placed on switchgear due to the connection of air conditioning	Insufficient available capacity for load	Potential load shedding or loss of switchgear due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2			
								Overhead Lines	Ambient temperature at a sustained high level	Capacity of overhead line reduced due to high ambient temperature	Insufficient available capacity for load	Potential load shedding or loss of circuit due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Potential	Review of Capacity of overhead lines to ensure fit for purpose in light of climate change predictions. Further include dynamic load ratings - monitor on site conditions and calculate real time rating										
								Additional load placed on circuit due to connection of air conditioning	Insufficient available capacity for load	Potential load shedding or loss of circuit due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of capacity of overhead lines to ensure fit for purpose in light of climate change predictions. Further include dynamic load ratings - monitor on site conditions and calculate real time rating			
								Increased sag	Insufficient clearances	Additional risk of bird activity contact with overhead line	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of spec for overhead line robust to ensure fit for purpose in light of climate change predictions			
								Underground Cables	Increase in ground temperature	Change in properties of soil	Reduction in capacity of cables due to change in soil temperature	Potential load shedding or loss of circuit due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Potential	Review of cable ratings in light of climate change predictions										
								Mechanical movement causes stress on cables and joints	Additional joint cable failures leading to loss of supplies	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	Planned
Mechanical movement causes stress on link boxes	Additional link box failures leading to loss of supplies	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4									
Protection																																								
Earthing																																								
Emergency Response & Planning	Ambient temperature at a sustained high level	High staff absence due to sickness	Reduced internal workforce	Staff re-allocation across the business required	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2																				
Vegetation Mgt	Ambient temperature at a sustained high level	Extended growing season	Additional encroachment of vegetation into overhead lines	Additional faults due to vegetation	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	In place	Vegetation programmes in place. Need to review in light of implications of climate change predictions on the growing season.																		
Routine Business (Maintenance, R&R, Capital Investment)	Ambient temperature at a sustained high level	Raised temperatures met that current PPE is unsuitable, particularly for live line work.	Routine work delayed due to weather condition	Planned work not delivered on time. Capital work and maintenance behind schedule	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2																				
Customer Service	Ambient temperature at a sustained high level	High staff absence due to sickness	Reduced internal workforce, potentially requiring additional contractors	Cost of work increases due to reduced bring in contractors at raised cost.	2	Unlikely	1	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	In place	Plan in place to ensure business as usual during periods of increased absence through staff re-deployment																		

Threat Type	Threat Type 2	Data Source	Data Type	Available Data				UKCP18 Update	Detail of Risks / Opportunities				Risk Assessment										Actions	Timescale (planned & potential actions)	Comments															
				Current	2020s	2050s	2080s		Asset Type	Projected direct or indirect impact	Risks and Opportunities	Consequences	Stakeholder impacts	Likelihood	Impact	2025s		2050s		2080s		Long Term Risk				Status	Details													
															Current Risk	Likelihood	Impact	Medium Term Risk	Likelihood	Impact	Likelihood	Impact																		
Extreme prolonged temperature periods (heat spell)	UKCP09	Mean winter temperature (central estimate)	31.1°C	All emissions scenarios: 4.4°C	L: 5.0°C M: 5.1°C H: 5.6°C	L: 6.1°C M: 6.1°C H: 6.7°C	Under RCP3 and 6.0 scenarios, warming forecast in line with UKCP09 high and medium scenarios for our region. Reduced warming forecast under lower scenarios.	Substations	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Insufficient available capacity for load	Potential load shedding or loss of transformer due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Annual review of loading of transformers against maximum demands to ensure adequate headroom on the network	All Northern Powergrid equipment is built to international, European and British standards which incorporate an amount of resilience. Due to the current varied global conditions, all standards currently allow for the equipment to operate in conditions which exceed those forecast to occur in the Northern Powergrid regions over the time period under consideration.										
								Transformers	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Insufficient available capacity for load	Potential load shedding or loss of transformer due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Review of transformer capacity to ensure fit for purpose in light of climate change predictions						
								Circuit Breakers	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Insufficient available capacity for load	Potential load shedding or loss of circuit breaker due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Regular inspections carried out to assess condition of lines and prior to replacement.						
								Overhead Lines	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Insufficient available capacity for load	Potential load shedding or loss of circuit due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of specification & capacity of overhead lines to ensure fit for purpose in light of climate change predictions						
								Underground Cables	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Insufficient available capacity for load	Potential load shedding or loss of circuit due to overload	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of specification & capacity of cables to ensure fit for purpose in light of climate change predictions						
								Protection																																
								Emergency Response & Planning	Ambient temperature at sustained low level	Increased loading on network due to additional heating and electrical appliances in use	Additional faults occur	Resources re-allocated more regularly leading to impact on business as usual.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place							
								Vegetation Mgt																																
								Routine Business (Maintenance, R&R, Capital Investment)																																
								Customer Service	Ambient temperature at sustained low level	Loss of supplies to vulnerable customers become greater	Need to reconnect any vulnerable customers as priority	Potential impact on customer service indicators	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Vulnerable customer identified on network						
Lightning	No predicts in currently available	Future predictions are uncertain. Caution approach to assume a small increase in lightning days until further research is presented.	Substations	Increased lightning storms	Increased number of lightning strikes	Additional faults occur	Customers off supply	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Lightning protection provided extensively on our network, with attention focused on known lightning hotspots. Protection includes AG-Substation Cells and known lightning hotspots	Lightning protection is provided extensively on our network, with attention focused on known lightning hotspots. Protection includes AG-Substation Cells and known lightning hotspots. Network performance is continuously assessed and any new initiatives which are considered to provide adequate cost benefits will be implemented on the network at appropriate locations.										
			Transformers	Increased lightning storms	Increased number of lightning strikes	Additional faults occur	Customers off supply	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Lightning protection provided across the network, targeted at known lightning hotspots											
			Circuit Breakers	Increased lightning storms	Increased number of lightning strikes	Additional faults occur	Customers off supply	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Lightning protection provided across the network, targeted at known lightning hotspots											
			Overhead Lines	Increased lightning storms	Increased number of lightning strikes	Additional faults occur	Customers off supply	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	Potential	Utilise IoT monitoring to give a better understanding of condition											
			Underground Cables																																					
			Protection																																					
			Emergency Response & Planning	Increased lightning storms	Increased number of lightning strikes	Additional damage to vegetation	Additional faults occur due to falling contact with vegetation	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place												
			Vegetation Mgt																																					
			Routine Business (Maintenance, R&R, Capital Investment)																																					
			Customer Service																																					
Gradual Temperature Increase	UKCP09	Mean summer temperature (central estimate)	14.2°C	L: 15.0°C M: 15.5°C H: 15.2°C	L: 16.4°C M: 16.3°C H: 16.8°C	L: 16.7°C M: 17.5°C H: 18.4°C	RCP3.5 projects a greater increase in summer mean temperature than the UKCP09 high scenario for our region. RCP3.5 is in line with the UKCP09 medium scenario and RCP3.5 analysis has been done on the number of days exceeding 28, 30 and 35 degrees celsius in the current climate it is relatively rare for a day to exceed 30 degrees celsius in our region. By mid century, the chance of a hot summer like 2018 will have increased from 10% to 50%. Largest increases in temperature will occur in South East England. By 2060, the hazards from temperature for our region are expected to be equivalent to SE England today.	Substations	Temperature rise	Reduction in ratings	Capacity of transformers reduced	Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Network capabilities & loadings regularly reviewed to identify any potential reinforcement requirements	All Northern Powergrid equipment is built to international, European and British standards which incorporate an amount of resilience. Due to the current varied global conditions, all standards currently allow for the equipment to operate in conditions which exceed those forecast to occur in the Northern Powergrid regions over the time period under consideration.										
								Transformers	Temperature rise	Reduction in ratings	Capacity of transformers reduced	Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Network capabilities & loadings regularly reviewed to identify any potential reinforcement requirements						
								Circuit Breakers	Temperature rise	Reduction in ratings	Capacities of switchgear reduced	Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Network capabilities & loadings regularly reviewed to identify any potential reinforcement requirements						
								Overhead Lines	Temperature rise	Reduction in ratings	Capacities of overhead line network reduced	Summer maintenance window reduced. Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Network capabilities & loadings regularly reviewed to identify any potential reinforcement requirements						
								Underground Cables	Temperature rise	Change in soil properties	Reduction in ratings of cables due to change in soil resistivity	Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review specification for cables to ensure sufficiency for standard loadings						
								Protection																																
								Emergency Response & Planning	Temperature rise	Extended growing season	Additional encroachment of vegetation into overhead lines	Negative impact on customer service indicators	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Vegetation programmes in place. Need to review in light of implications of climate change predictions on the growing season.						
								Vegetation Mgt																																
								Routine Business (Maintenance, R&R, Capital Investment)																																
								Customer Service																																
Drought (oil drying & movements)	UKCP09	Mean summer temperature (central estimate) (delta increase in air temp is reflected by a 0.75°C increase in soil temp at depths of between 0.45 & 1.2m)	14.2°C	L: 15.0°C M: 15.5°C H: 15.2°C	L: 16.4°C M: 16.3°C H: 16.8°C	L: 16.7°C M: 17.5°C H: 18.4°C	Changes in precipitation trends across all scenarios are roughly in line with those predicted in UKCP09 for our region. Significant variation can be found across the UK with the driest areas in the SE and the wettest in the west and highlands. In general there is little reduction in seasonal rainfall forecast. Summer rainfall increases greater in the North of the UK. RCP3.5 projects a greater increase in summer mean temperature than the UKCP09 high scenario for our region. RCP3.5 is in line with the UKCP09 medium scenario and RCP3.5 analysis has been done on the number of days exceeding 28, 30 and 35 degrees celsius in the current climate it is relatively rare for a day to exceed 30 degrees celsius in our region. The temperature exceeds 38 degrees for 3 consecutive days on average 4 times per year. By mid century, the chance of a hot summer like 2018 will have increased from 10% to 50%. Largest increases in temperature will occur in South East England. By 2060, the hazards from temperature for our region are expected to be equivalent to SE England today.	Substations	Change in soil condition of foundations	Subsidence	Substation subject to instability	Risk to staff and public should the building become unstable	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Existing substations subjected to inspections to ensure integrity. Ensure soil type and suitability is considered in locating new substations											
								Transformers	Change in soil condition of foundations	Subsidence	Transformer foundation instability	Risk to staff should the transformer become unstable	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Existing substations subjected to inspections to ensure integrity. Ensure soil type and suitability is considered in locating new substations						
								Circuit Breakers	Change in soil condition of foundations	Subsidence	Switchgear mounting subject to instability	Risk to staff should the switchgear mounting become unstable	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Existing substations subjected to inspections to ensure integrity. Ensure soil type and suitability is considered in locating new substations						
								Overhead Lines	Change in soil condition of foundations	Subsidence	Poles / towers become unstable	Risk to staff and public should the power tower become unstable	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	In place	Existing poles/towers subjected to inspections to ensure integrity.						
								Underground Cables	Change in water content of soil	Adverse effect on soil wetting	Reduction in ratings of cables due to change in soil resistivity	Network capabilities reduced leading to need for additional reinforcement.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of cable ratings in light of climate change predictions						
								Protection																																
								Emergency Response & Planning	Change in water content of soil	Adverse effect on soil wetting	Earthling may become less effective	Risk to safety if equipment not adequately earthed	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	2	Unlikely	2	Minor	4	Potential	Review of earthing policy in light of climate change predictions						
								Vegetation Mgt	Change in natural habitats of different species	Change in natural habitats of different species	Type of vegetation in an area changes	Vegetation may be impacted in incorrect areas.	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	2	Unlikely	1	Limited	2	Potential	Review of vegetation management programmes in light of changes to habitat						
								Routine Business (Maintenance, R&R, Capital Investment)																																
								Customer Service																																
Wildfire	Not considered	Increasing risk of wildfire in future climates. Increased severity and frequency of fire weather conditions, increased fuel loading and flammability hazard of vegetation result in increased risk of wildfire. Can be exacerbated by extreme temperatures, drought and wind.	Substations	Fire occurs	Transformer's catch fire	If filled with oil the risk of fire	Loss of supplies could occur	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	Potential	Look to utilise synthetic poles in place of oil in at risk areas											
			Overhead Lines	Fire occurs	Damage to oil and oil equipment	Poles damaged by fire	Failures leading to customers off supply	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	In place	Use of preservative on wood poles helps to prevent fire damage											
			Underground Cables	Fire occurs	Damage to cable and cable equipment	Cable terminations damaged by fire	Additional failures occur leading to loss of supply	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	Potential												
			Protection																																					
			Emergency Response & Planning																																					
			Vegetation Mgt																																					
			Routine Business (Maintenance, R&R, Capital Investment)																																					
			Customer Service																																					
			Substations	Internal heat in vicinity of cables	Dis-rating occurs due to the heat of the fire	Network capabilities reduced		1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	Minor	2	Potential										
			Underground Cables	Damage to link box	Link box damaged by fire	Additional failures occur leading to loss of supply		1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	1	Very Unlikely	2	Minor	2	Minor	2	Potential										